


ITEMS	
A	AUTOMATIC AIR VENT
B	VACUUM BREAKER
C	SEPARATOR
D	STEAM TRAP WITH STRAINER
E	STRAINER WITH VALVE
F	MAIN STEAM TRAP
G	HORIZONTAL COIL
H	MIXER (SEE DWG. M.I.-29-A)

NOTE:
 1. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT
 2. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT AND NON INSULATED
 3. DRAIN DURING SHUT DOWN

IF THE RETURN CANNOT BE BY GRAVITY, PROVIDE THE RETURN WITH THE HELP OF A PUMP OR INSTALL A SAFETY DRAIN. REFERENCE DRAWING M.I.-04,1,3,14&16

CUSTOMER:	
PROJECT:	
TITLE: HORIZONTAL FEED COIL OPPOSITE CONNECTIONS	
DWG. NO.:	REV. NO.:
M. I. -05-A	
DATE: 06-12-2004	



MAXI THERM
maxi-therm.net