



NOTE # 1

NOTE # 3

CONDENSATE RETURN
BY GRAVITY

ITEMS

- (A) AUTOMATIC AIR VENT
- (B) VACUUM BREAKER
- (C) SEPARATOR STEAM / WATER
- (D) STEAM TRAP WITH STRAINER
- (E) STRAINER WITH VALVE
- (F) MAIN STEAM TRAP
- (G) EXCHANGER SHELL/TUBE
- (H) MIXER
(SEE DRAWING M.I.-29-A)

IF THE RETURN CANNOT BE BY GRAVITY, PROVIDE THE RETURN WITH THE HELP OF A PUMP OR INSTALL A SAFETY DRAIN. REFERENCE DRAWING M.I.-4,13,14 & 16

- NOTE:
1. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT
 2. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT AND NON INSULATED
 3. DRAIN DURING SHUT DOWN

CUSTOMER:

PROJECT:

TITLE:

EXCHANGER SHELL/TUBE

DWG.NO.:	M.I.-10-A	REV.NO.:	
DATE:	06-12-2004		

