



ITEMS

A AUTOMATIC AIR VENT

B VACUUM BREAKER

C SEPARATOR

D STEAM TRAP WITH STRAINER

E MAIN STEAM TRAP

F STRAINER WITH VALVE

G VERTICAL EXCHANGER

H MIXER (SEE DWG M.T.-29-A)

OPTION 1
INSTALL ITEMS A&B AT INLET IF MAIN STEAM TRAP IS THERMOSTATIC

IF THE RETURN CANNOT BE BY GRAVITY, PROVIDE THE RETURN WITH THE HELP OF A PUMP OR INSTALL A SAFETY DRAIN. REFERENCE DRAWING M.T.-04.13.14&16

- NOTE:
1. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT
 2. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT AND NON INSULATED
 3. DRAIN DURING SHUT DOWN

CUSTOMER:

PROJECT:

TITLE: VERTICAL EXCHANGER

DWG.NO.: M.T.-11-A

REV.NO.:

DATE: 06-12-2004

