



ITEMS

- A) STEAM TRAP
- B) VERTICAL EXCHANGER
- C) SAFETY TRAP
- D) EXISTING CIRCULATING PUMP
- E) SEPARATOR OR STRAINER
- F) BIMETALLIC STEAM TRAP
- G) AUTOMATIC AIR VENT
- H) PNEUMATIC CONTROL VALVE
- I) ELECTRIC PROBE
- J) MIXER
- K) ELECTRIC TEMPERATURE PROBE TO AUTOMATION OR PNEUMATIC CONTROLLER WITH 3-15 PSI SIGNAL TO VALVE H

NOTE : 1. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT  
 2. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT AND NON INSULATED  
 3. DRAIN DURING SHUT DOWN

CUSTOMER :

PROJECT :

TITLE :

INSTANTANEOUS WATER HEATER WITH ACCUMULATION TANK FLOODED METHOD

DESSIN No. : M.T.-12E-A REV. No. : 00

PAR : C.CAROLI DATE : 08.12.2004

