



ITEMS

(A)	STEAM TRAP
(B)	VERTICAL EXCHANGER
(C)	SAFETY VALVE
(D)	EXISTING CIRCULATION PUMP
(E)	STRAINER
(F)	EXISTING STEAM TRAP
(G)	AUTOMATIC AIR VENT
(H)	PNEUMATIC CONTROL VALVE
(I)	STABILIZATION PUMP
(J)	EXISTING SAFETY
(K)	PNEUMATIC CONTROLLER WITH SIGNAL 3-15 PSI TO VALVE H

NOTE: 1. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT
 2. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT AND NON INSULATED
 3. DRAIN DURING SHUT DOWN

CUSTOMER:

PROJECT:

TITLE:

INSTANTANEOUS WATER HEATER
 FLOODED METHOD

DWG. No.: M.T.-12F-A REV. No.: 00

BY: C.CAROLI DATE: 18.12.2004

