



ITEMS

- A) AUTOMATIC AIR VENT
- B) VACUUM BREAKER
- C) SEPARATOR
- D) STEAM TRAP
- E) STRAINER WITH VALVE
- F) MAIN STEAM TRAP
- G) MIXER ( SEE DRAWING M.T.-29-A)

IF THE RETURN CANNOT BE BY GRAVITY, PROVIDE THE RETURN WITH THE HELP OF A PUMP OR INSTALL A SAFETY DRAIN. REFERENCE DRAWINGS M.T.-4,13,14 & 16

- NOTE: 1. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT  
 2. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT AND NON INSULATED  
 3. DRAIN DURING SHUT DOWN

CUSTOMER:

PROJECT:

TITLE:  
 CONVENTIONAL  
 HOT WATER TANK

DWG.NO.: M.T.-18-A	REV.NO.:
DATE: 09-12-2004	

