

ITEMS

(A)	HUMIDIFIER
(B)	CONTROL VALVE ACTUATOR
(C)	SEPARATOR
(D)	STEAM TRAP
(E)	STEAM TRAP
(F)	PIPING VARIES ACCORDING TO CAPACITE

IF THE RETURN CANNOT BE BY GRAVITY, PROVIDE THE RETURN WITH THE HELP OF A PUMP OR INSTALL A SAFETY DRAIN. REFERENCE DRAWINGS M.T.-4,13,14 & 16

NOTE: 1. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT  
 2. SAME DIAMETER AS THE OUTLET OF THE EQUIPMENT AND NON INSULATED  
 3. DRAIN DURING SHUT DOWN

CUSTOMER:

PROJECT:

TITLE:

HUMIDIFICATION  
 MULTIPLES DISTRIBUTORS  
 MODEL CS-3110

DWG. No.: M.T.-33-A REV. No.: 00

DATE: 16-12-2004

